

PROJECT: REPLACEMENT OF 2-UNITS 30TR AIR HANDLING UNIT (AHU) AT THE 2ND FLOOR OF SSS MAKATI BUILDING

A. QUERIES/CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE:

	Query/Clarifications	TWG/BAC Reply
1	When can we conduct survey? Can we get the names of the people that are on duty at the site?	Anytime. There are personnel assigned on duty at the site. We will send you an email with the names of the contact persons for your reference. We will send also the names in the chat box of this conference.
2	In the premise that all bidders will conduct site inspection, it was scheduled 5 days after this Pre-Bid, including weekends.	Site inspection will be on December 15 to 19, 2021.
3	Just a clarification in the equipment description, Air Handling ducted, is it water cooled?	Yes. It is water cooled.
4	What is the diameter of the pipe and the water temperature required for this?	During your site inspection you will be able to observe it.
5	Is Phil-GEPS mayor's permit with validity up to December 31, 2021, still acceptable?	Yes. It's still acceptable..
6	Is payment for Bid Docs online? Is it downloadable?	For this payment, we do not have any online options. Payments can be made in the morning of January 05, 2022 upon submission of your documents before 2:00 p.m. Bid Docs are available for download, and we have already sent you a copy. You can request a copy of this via email if you don't already have one.

B. REPLY TO WRITTEN QUERIES/CLARIFICATIONS:

	Query/Clarifications	TWG Reply
1	I would like to clarify if the dismantling and relocation of the existing equipment would be part of the bidder's scope.	No. The installed AC Equipment will be dismantled by the existing service provider