**PROJECT:**       SUPPLY, DELIVERY AND INSTALLATION OF UPS BATTERIES FOR SSS BRANCHES AND PROCESSING CENTER

**QUERIES/CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE:**

| | Query/Clarifications | TWG/BAC Reply |
|---|---|---|
| 1 | Clarification regarding the delivery schedule of the project: Is it correct that the delivery period of the project is ninety (90) days after the contract approval? | Yes. |
| 2 | Clarification regarding the SLCC: Their other client from another government agency has a 25% mandatory requirement for their ABC, can SSS work-out the same requirement for the ABC? | No. The SLCC shall be at least 50% of the ABC |
| 3 | Is the project exclusive for UPS only or including UPS Batteries? | The SLCC shall be supply, delivery and installation of UPS Batteries or Supply, delivery and installation of UPS project/contract provided that the value or cost of battery is clearly stated or separately indicated in the contract and the value of which shall be at least 50% of the ABC. |
| 4 | Is the project one lot only? | Yes. |
| 5 | Is the outlet cable included? | Battery cable from battery bank breaker to UPS terminal shall be re-used. Intercell battery wires shall be new and to be provided by the supplier with appropriate fitting |

**WRITTEN QUERIES:**

| | Query/Clarifications | TWG/BAC Reply |
|---|---|---|
| 1 | Single Largest Completed Contract (SLCC) – Can we use Supply, Delivery and Installation UPS | The SLCC shall be supply, delivery and installation of UPS Batteries or Supply, delivery and installation UPS project/contract provided that the value or cost battery is clearly stated in the contract and the value of which shall be at least 50% of the ABC. |
| 2 | For Item 4 requirement (12V, 40AH) – Can we use/offer 12V, 42 AH | For item 4, the 12V, 42 AH offer is acceptable provided that it complies with the prescribed dimension/sizes. |
| 3 | For Item 5 requirement (12V, 45AH) – Can we use/offer 12V, 42 AH | For item 5, the 12v, 42 AH offer is not acceptable |
| 4 | Can we please request if the lead-time can extend form 90 days to 150 days | The project lead time or contract duration of 90 calendar days cannot be extended |